

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 897 - 897

Dated: 15.06.2023

It is certified that an inspection team headed by Virendra Singh Choudhary(Name of Officers with designation) from Nagar Palika Bagar(Name of Department/ Office) inspected the Shri Hanuman Bux Gograj Bagaria Public Sr. Sec. School, Bagar(Name & Address of the school) on 15.06.2023 (date of inspection) and found that theSr. Sec. School, Bagar (Name of school) has ~~safe drinking water~~ facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.The above is valid for a period of 15.06.2024Signature with Seal: [Signature]Name: [Name]Designation: E. O.Name & Address of the Office / Department: Nagar Palika Bagar

To

Shri Hanuman Bux Gograj Bagaria Public Sr. Sec. School, Bagar

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

[Signature]
SecretaryS. H. G. B. Sr. Sec. Public School
Bagar (Jhunjhunu)[Signature]
PrincipalSHB Gograj Bagaria Sr. Sec. Public School
CBSE Aff. No. 1731013 BAGAR, JLN-333023



PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2022-23/ 597

Date - 16-11-2022

To,
The Principal
SHGB Sr Sec School
Bagar

Distt:-Jhunjhunu


Tehsil:-Jhunjhunu

Ref- Your's letter dated 6-11-2022


Date of Exam -16-11-2022

A	Name & Location of Source		Water Sample SHGB Sr Sec School Bagar
B	Village/ Town		Bagar
C	Date Of Collection		16-11-22
D	Lab. Sample No.		C-26
Sr. No	Parameters	Permissible limits	Analysed Value
1	pH	6.5—8.5	7.4
2	Turbidity[NTU]	5	Nil
3	Temperature[C]	-----	25
4	Colour[Units]	25 Hazen Unit	None
5	Odour	Unobjectionable	Unobj.
6	Total Alkalinity[asCaCO ₃]	600	50
7	Total Hardness[asCaCO ₃]	600	50
8	Calcium [asCa]		8
9	Magnesium [as Mg]		7.2
10	Chloride[asCl ⁻¹]	1000	30
11	Nitrate[as NO ₃ ⁻¹]	45	4
12	Fluoride [as F ⁻¹]	1.5	0.21
13	TDS	2000	126


Note: All Results Except pH in mg/L.


(S K Sharma)
Junior Chemist

PHED Laboratory Jhunjhunu


Secretary

B. Sr. Sec. Public School
Bagar (Jhunjhunu)


Principal

SHB Gograj Bagaria Sr. Sec. Public School
CBSE Affi. No.1731013 BAGAR, JHUNJHUNU